

Combustible Dust

Does your company or firm process any of these products or materials in powdered form?

If your company or firm processes any of these products or materials, there is potential for a "Combustible Dust" explosion.

<p>Agricultural Products</p> <p>Egg white Milk, powdered Milk, nonfat, dry Soy flour Starch, corn Starch, rice Starch, wheat Sugar Sugar, milk Sugar, beet Tapioca Whey Wood flour</p>	<p>Cottonseed Garlic powder Gluten Grass dust Green coffee Hops (malting) Lemon peel dust Lemon pulp Linseed Locust bean gum Malt Oat flour Oat grain dust Olive pellets Onion powder Parsley (dehydrated) Peach Peanut meal and skins Peat Potato Potato flour Potato starch Raw yucca seed dust Rice dust Rice flour Rice starch Rye flour Semolina</p>	<p>Soybean dust Spice dust Spice powder Sugar (10x) Sunflower Sunflower seed dust Tea Tobacco blend Tomato Walnut dust Wheat flour Wheat grain dust Wheat starch Xanthan gum</p>	<p>Chemical Dusts</p> <p>Adipic acid Anthraquinone Ascorbic acid Calcium acetate Calcium stearate Carboxy-methylcellulose Dextrin Lactose Lead stearate Methyl-cellulose Paraformaldehyde Sodium ascorbate Sodium stearate Sulfur</p>	<p>Epoxy resin Melamine resin Melamine, molded (phenol-cellulose) Melamine, molded (wood flour and mineral filled phenol-formaldehyde) (poly) Methyl acrylate (poly) Methyl acrylate, emulsion polymer Phenolic resin (poly) Propylene Terpene-phenol resin Urea-formaldehyde/cellulose, molded (poly) Vinyl acetate/ethylene copolymer (poly) Vinyl alcohol (poly) Vinyl butyral (poly) Vinyl chloride/ethylene/vinyl acetylene suspension copolymer (poly) Vinyl chloride/vinyl acetylene emulsion copolymer</p>
<p>Agricultural Dusts</p> <p>Alfalfa Apple Beet root Carrageen Carrot Cocoa bean dust Cocoa powder Coconut shell dust Coffee dust Corn meal Cornstarch Cotton</p>	<p>Carbonaceous Dusts</p> <p>Charcoal, activated Charcoal, wood Coal, bituminous Coke, petroleum Lampblack Lignite Peat, 22%H_2O Soot, pine Cellulose Cellulose pulp Cork Corn</p>	<p>Metal Dusts</p> <p>Aluminum Bronze Iron carbonyl Magnesium Zinc</p>	<p>Plastic Dusts</p> <p>(poly) Acrylamide (poly) Acrylonitrile (poly) Ethylene (low-pressure process)</p>	

Dust Control Measures

The dust-containing systems (ducts and dust collectors) are designed in a manner (i.e., no leaking) that fugitive dusts are not allowed to accumulate in the work area.

The facility has a housekeeping program with regular cleaning frequencies established for floors and horizontal surfaces, such as ducts, pipes, hoods, ledges, and beams, to minimize dust accumulations within operating areas of the facility.

The working surfaces are designed in a manner to minimize dust accumulation and facilitate cleaning.

Ignition Control Measures

Electrically-powered cleaning devices such as vacuum cleaners, and electrical equipment are approved for the hazard classification for Class II locations.

The facility has an ignition control program, such as grounding and bonding and other methods, for dissipating any electrostatic charge that could be generated while transporting the dust through the ductwork.

The facility has a Hot Work permit program.

Areas where smoking is prohibited are posted with "No Smoking" signs.

Duct systems, dust collectors, and dust-producing machinery are bonded and grounded to minimize accumulation of static electrical charge.

The facility selects and uses industrial trucks that are approved for the combustible dust locations.

Prevention Measures

The facility has separator devices to remove foreign materials capable of igniting combustible dusts.

MSDSs for the chemicals which could become combustible dust under normal operations are available to employees.

Employees are trained on the explosion hazards of combustible dusts.

Protection Measures

The facility has an emergency action plan.

Dust collectors are not located inside of buildings. (Some exceptions)

Rooms, buildings, or other enclosures (dust collectors) have explosion relief venting distributed over the exterior wall of buildings and enclosures.

Explosion venting is directed to a safe location away from employees.

The facility has isolation devices to prevent deflagration propagation between pieces of equipment connected by ductwork.

The dust collector systems have spark detection and explosion/deflagration suppression systems.

Emergency exit routes are maintained properly.

