



### Warnings

No warnings.

### Simulation Tips

Daysim generates a schedule file, that can be linked to a thermal simulation program. To open file click the link below

C:\DIVA  
 \temp\Rhino30WWR-  
 KL\Rhino30WWR-  
 KL\_intgain.csv

## Daysim Simulation Report

Daylit Area (DA <sub>300lux</sub> [50%])	84% of floor area
Mean Daylight Factor	3.7%
Occupancy	3393 hours per year

**Daylight Factor (DF) Analysis:** 48% of all illuminance sensors have a daylight factor of 2% or higher. Assuming that the sensors are evenly distributed across 'all spaces occupied for critical visual tasks', the investigated lighting zone does **not** qualify for LEED-NC 2.1 daylighting credit 8.1.

**Daylight Autonomy (DA) Analysis:** The mean daylight autonomy is 67% for active occupant behavior. The percentage of the space with a daylight autonomy larger than 50% is 84% for active occupant behavior.

**Continuous Daylight Autonomy (DA) Analysis:** The mean continuous daylight autonomy is 76% for active occupant behavior. The percentage of sensors with a DA\_MAX > 5% is 48% for active occupant behavior.

**Useful Daylight Illuminance (UDI):** The percentage of the space with a UDI<sub><100-2000lux</sub> larger than 50% is 79% for active occupant behavior.

**Electric Lighting Use:** The predicted annual electric lighting energy use is:

- Lighting Group 1 (occ\_dimming): 1026.7 kWh
- Lighting Group 2 (occ\_dimming): 876.7 kWh

## Simulation Assumptions

### Site Description:

The investigated building is located in SANTIAGO\_CHL (33.38 S/ 70.78 E).


### User Description:

The total annual hours of occupancy at the work place are 3393.




### Lighting Control:

- Lighting Group 1 (occ\_dimming): The system has an installed electric lighting power of 1245.0W. It is manually controlled with an on/off switch combined with a switch off occupancy sensor with a delay time of 5 minutes. The occupancy sensor only switches the lighting off (not on!). The dimming system has an ideally commissioned photocell control with a ballast loss factor of 0.00 percent. The lighting system has a total standby power of 0.00W.



- Lighting Group 2 (occ\_dimming): The system has an installed electric lighting power of 1245.0W. It is manually controlled with an on/off switch combined with a switch off occupancy sensor with a delay time of 5 minutes. The occupancy sensor only switches the lighting off (not on!). The dimming system has an ideally commissioned photocell control with a ballast loss factor of 0.00 percent. The lighting system has a total standby power of 0.00W.



### ShadingControl:

There is no dynamic shading system in the scene.